

## **SPECIFICATION FOR DRIZIT® CHEMICAL SPILL KIT 1000**



	0274/10
Container Size	150 x 107 x 126 cm
Container Volume	1000 litres
Container Colour	Blue
Pack Wt (gross)	132.6 kg
Sorbency	394- 663 litres

Sorbency: Lower figure test method to BS 7959-1:2004 using water. Higher figure based on high viscosity liquid with no drain

Container:	Heavy duty, UV stabilised highly visible, water proof bunker with forklift access. Fully opening lid allows for ease of access to contents.
Contents:	<ul> <li>200 Chemical Pads</li> <li>2 Chemical Mini Rolls</li> <li>10 Chemical Socks 125 x 7.5 cm</li> <li>4 Chemical Socks 300 x 7.5 cm</li> <li>2 Chemical Booms 400 x 12.5 cm</li> <li>2 Chemical Booms 400 x 20 cm</li> <li>10 Chemical Cushions</li> <li>1 Dammit<sup>®</sup> X Mat 65 x 45 cm</li> <li>1 Dammit<sup>®</sup> X Ready Mix 800g</li> <li>2 Wooden Stakes</li> <li>10 Disposal bags and ties</li> </ul>
Replenishment:	A full refill kit is available for this product. Please use code 0274/10/R. To order further kits, refill sets or packs of individual items please contact us.
Instructions for use:	It is important that a suitable and sufficient Risk Assessment is carried out on each incident and correct PPE is worn. Depending on the nature of the spill a combination of the contents of the kit may be used.
Compatibility:	The absorbents within this kit may be safely used with all aqueous solutions and liquids immiscible with water, such as hydrocarbons, solvents, mineral oils, <i>with the exception of strong oxidising agents</i> . Before any use in a spill situation a proper risk assessment should be carried out and all hazardous properties of the liquid or dangerous reactions taken into account.

Revision Date: 06/11/2018





## **N** Product Focus



Disposal:	Used sorbents may be disposed of by landfill or incineration, in accordance with local and national regulations, taking into account the classification of the liquid absorbed.
Safety Data:	Further technical advice is available if required.
Note:	All weights, dimensions, and other figures quoted are approximate.

Revision Date: 06/11/2018



